Public Spa Pool Daily Record Sheet

Date: _____ **Name of Pool:** _____ **Manager:** _____ **Operator:** _____

31	30	29	28	27	26	25	24	23	22	21	20	19	18	17	16	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	Day of the Month		
																															Time	Bromine – ppm Test Hourly	Free Chlorine (DPD #1) ppm Total Chlorine (DPD #3) ppm Test Hourly Stabilized – Every 2 Hours
																															Cyanuric Acid (Weekly) w/stabilized chlorine		
																															Alkalinity (Daily)		
																															Acid Added		
																															Soda Ash Added		
																															Emptied Pool		
																															Super-chlorinated or Oxidized		
																															Calcium Hardness		
																																	PH – Test Every 2 Hours

Water Quality Parameters – (333-62-165)

	MINIMUM	IDEAL	MAXIMUM
Free Chlorine	1.5 ppm	3.0 ppm	5.0 ppm
Combined Chlorine	0	0	0.5 ppm
Bromine	3.0 ppm	3.0-5.0 ppm	8.0 ppm
pH	7.2	7.4-7.6	7.6
Total Alkalinity	80 ppm	100-125 ppm	175 ppm
Cyanuric Acid	30 ppm	--	150 ppm
Calcium Hardness	100 ppm	200 ppm	--
Temperature	--	--	104°F

NOTES: Spa Pool Closure: _____

_____

Other Information: _____

_____